UPPER DARBY TOWNSHIP FIRE DEPARTMENT

FIRE HEADQUARTERS

7216 WEST CHESTER PIKE – UPPER DARBY, PA 19082 610.734.7673 FAX 610.734.7658

Interim Chief of Department BRIAN BOYCE



Deputy Chiefs KEITH C. YASHIN WILLIAM NORRIS MARK MORRISSEY DENNIS GALLAGHER

Common Violations Found During a Fire Inspection

- 1. Inspected fire extinguisher(s) and provide an annual service.
- 2. Maintain a 30" clearance in front of, and clear access to, all electrical panels.
- 3. Provide cover plates to all open electrical boxes and switches.
- 4. The use of extension cords and multi-plug adapters. (UL listed multiple-outlet strips with circuit breakers are acceptable).
- 5. Maintained fire doors in their automatic self-closing and latching condition. Remove all wedges and door stops.
- 6. Ensure secondary exits are clearly marked; ensure that illuminated exit signs are fully and always lit.
- 7. Remove obstructions and/or combustible materials from exit-ways, stairways, and fire escapes
- 8. Provide approved address identification for building including suite or unit numbers (letters), plainly visible and contrasting to background color.
- 9. Remove combustible materials stored in boiler/heater rooms.
- 10. Inspected fire alarm system annually and provide an inspection report.